

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1209:208 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles IL 60174  
Contact: Trish Linhart (630) 377-6674 FAX (630) 377-7245

**DESIGN:** Models S1215K, S121575K, S2415K, S2430K, S2460K, S2475K, S24110K, and S241575K strobe lights. Model number may be suffixed by letter -W (white color) and/or -F, -AG or -EV. Intended for indoor or outdoor use on wall only.

\*Models S1224MCK (red housing) and S1224MCWK (white housing) strobe lights. Intended for indoor or outdoor use on a wall only.

\*Models S2475, strobe light followed by RLP, ALP, GLP, OR BLP, may or may not be followed by W. Intended for indoor use on the wall only.

\*Model DS2475 Strobe light followed by W (white) and/or A, R, B, and/or G. Intended for indoor use on the wall or ceiling.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** All Models = 12-volt: 10.5 - 17 Vdc/Fwr\*  
24-volt: 20 - 30 Vdc/Fwr\*

\*Models S1224MCK, -MCWK = 12-volt: 9.5 - 17.5 Vdc/Fwr  
24-volt: 16 - 33 Vdc/Fwr  
Selectable Candela: 12V: 15, 15/75cd  
24V: 15, 15/75, 30, 75, 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as non-hearing impaired visual signaling appliances for use with separately listed compatible fire alarm control units. May be used outdoor when mounted on Model WBB backbox. Not suitable for the hearing-impaired application.

**NOTE:** Not to be used as a Visual Public Mode Alarm Notification Appliance.

\*Rev. 03-01-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**